



4240 Passmore Upper Road, Winlaw BC, V0G2J0
250-226-7339
test@passmorelaboratory.ca
passmorelaboratory.ca

Client Wynndel Irrigation District
Attention Bob Adams

CERTIFICATE OF ANALYSIS

<u>Analyses</u>	<u>Method Description</u>	<u>Reference</u>
Total Coliforms	Membrane Filtration on LES Endo medium	APHA 9222B
E. coli	MF Partition on NA-MUG medium	APHA 9222I

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA. Passmore Laboratory assumes no responsibility for any loss or damage resulting from error or omission in the conduct of testing. Liability is limited to the cost of the analysis.

Processed by: Melina Plotz

Mechelle Babic,
Lab Manager

Please call or Email for with any questions, feedback, or more information

ANALYTICAL RESULTS

Sample ID	Wynndel store			Sample #	1	
Date/Time Sampled	2023-12-12	10:45 AM	Matrix	DW	Temperature on Receipt	6

Date/Time on Test 2023-12-13 1:57 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>
Coliforms, Total	less than 1	CFU/100mL	1
Verified E.coli	less than 1	CFU/100mL	1

Glossary of Terms

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Pubic Health Association
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW =Treated water, DW= Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References